

NEM Reliability Standard – Generation and Bulk Supply¹

This Reliability Standard for Generation and Bulk Supply was determined by the Reliability Panel (Panel) as part of its Comprehensive Reliability Review (CRR), which it completed on 30 November 2007. This Reliability Standard forms part of the *power system security and reliability standards* and was determined in accordance with clauses 8.8.1(a)(2) and 8.8.3 of the National Electricity Rules (Rules).

Form of the Reliability Standard

The NEM Reliability Standard for Generation and Bulk Supply is an output-based measure expressed in terms of the maximum permissible unserved energy (USE), or the maximum allowable level of electricity at risk of not being supplied to consumers, per financial year. The USE is measured in GWh and should be expressed as a percentage of the annual energy consumption for the associated region or regions.

Level of the Reliability Standard

The maximum permissible unserved energy (USE), or the maximum allowable level of electricity at risk of not being supplied to consumers, is 0.002% of the annual energy consumption for the associated region or regions per financial year.

Compliance with the Reliability Standard

Compliance with this Reliability Standard for Generation and Bulk Transmission should be measured over the long-term using a moving average of the actual observed levels of annual USE for the most recent 10 financial years.

Operationally, this Reliability Standard for Generation and Bulk Transmission should be targeted to be achieved in each financial year, for each region and for the NEM as a whole.

Scope of the Reliability Standard

This Reliability Standard for Generation and Bulk Supply includes unserved energy associated with power system reliability incidents that results from:

- a single credible contingency on a generating unit or an inter-regional transmission element, that may occur concurrently with planned generating unit or inter-regional transmission element outages; or
- delays to the construction or commissioning of new generating units or inter-regional transmission network elements, including delays due to industrial action or ‘acts of God’.

This Reliability Standard for Generation and Bulk Supply excludes unserved energy associated with power system security incidents that results from:

- multiple or non-credible contingencies;
- planned outages of intra-regional transmission or distribution network elements; or
- industrial action or ‘acts of God’ at existing generating or inter-regional transmission facilities.

¹ This standard is published in the final report of the Reliability Panel’s Comprehensive Reliability Review, available on the AEMC website at <http://www.aemc.gov.au/electricity.php?r=20051215.142656>.