



National Electricity Amendment (Victoria Generator Technical Performance Standards Derogations) Rule 2010 No. 10

under the National Electricity Law as applied by:

- (a) the National Electricity (South Australia) Act 1996;
- (b) the Electricity (National Scheme) Act 1997 of the Australian Capital Territory;
- (c) the Electricity - National Scheme (Queensland) Act 1997 of Queensland;
- (d) the Electricity - National Scheme (Tasmania) Act 1999 of Tasmania;
- (e) the National Electricity (New South Wales) Act 1997 of New South Wales;
- (f) the National Electricity (Victoria) Act 2005 of Victoria; and
- (g) the Australian Energy Market Act 2004 of the Commonwealth.

The Australian Energy Market Commission makes the following Rule under the National Electricity Law.

John Pierce
Chairman
Australian Energy Market Commission

National Electricity Amendment (Victoria Generator Technical Performance Standards Derogations) Rule 2010 No. 10

1 Title of Rule

This Rule is the *National Electricity Amendment (Victoria Generator Technical Performance Standards Derogations) Rule 2010 No.10*.

2 Commencement

This Rule commences operation on 16 September 2010.

3 Amendment of the National Electricity Rules

The National Electricity Rules are amended as set out in Schedule 1.

Schedule 1 Amendments of the National Electricity Rules

(Clause 3)

[1] Schedule 9A3 Jurisdictional Derogations Granted to Generators

In Schedule 9A3 in Chapter 9, omit clause 4 and substitute "[Deleted]".

[2] Schedule 9A3 Jurisdictional Derogations Granted to Generators

In Schedule 9A3 in Chapter 9, omit Table 2 in clause 5 and substitute:

Table 2:

Generator	Generating Unit	Leading Power Factor
Smelter Trader	Anglesea Power Station Unit 1	0.991

[3] Schedule 9A3 Jurisdictional Derogations Granted to Generators

In Schedule 9A3 in Chapter 9, omit clauses 6, 7, 10 and 11 and substitute "[Deleted]" in each case.

[4] Schedule 9A3 Jurisdictional Derogations Granted to Generators

In Schedule 9A3 in Chapter 9, omit clause 13 and substitute:

For the purposes of clause S5.2.5.11 of schedule 5.2 of the *Rules*, a *Generator* listed in Table 10 is not required to include *facilities* for load control for the *generating unit* listed in column 2 of Table 10.

Table 10:

Generator	Generating Unit
Smelter Trader	Anglesea Power Station Unit 1

[5] Schedule 9A3 Jurisdictional Derogations Granted to Generators

In Schedule 9A3 in Chapter 9, omit clauses 14 and 15 and substitute "[Deleted]" in each case.

[6] Schedule 9A3 Jurisdictional Derogations Granted to Generators

In Schedule 9A3 in Chapter 9, omit clause 16 and substitute:

For the purposes of clause S5.2.5.13(b) of schedule 5.2 of the *Rules*, a *Generator* listed in Table 13 is not required to provide *power system* stabilising action in relation to the *generating unit* listed in column 2 of Table 13.

Table 13:

Generator	Generating Unit
Smelter Trader	Anglesea Power Station Unit 1

[END OF RULE AS MADE]
